



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	8170-2378:0001
CATEGORY:	8170 - IGNITION-RESISTANT MATERIALS
LISTEE:	ABET USA Inc. N48W37031 E. Wisconsin Avenue, Oconomowoc, WI, 53006 Contact: Musielak, Matthew (262) 560-4435 Email: MMusielak@fiberesin.com
DESIGN:	MEG (Material Exterior Grade), 4-1/4' feet width x 0.315 inch thick x 10 feet length, thermally fused exterior wall panel. Refer to manufacturer's installation instructions and product data sheets for additional detailed product description and construction.
RATING:	Flame Spread Index: 5 Maximum Flame Front less than 10.5 feet
INSTALLATION:	In accordance to Listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee name, Model number, rating and Intertek label.
APPROVAL:	Listed as an ignition resistant material when used in the Wildland Urban Interface areas. Refer to listee's Installation Instruction Manual for details.
NOTES:	Tested to ASTM E2768

11-27-2023



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 11/29/2023

Listing Expires: 06/30/2024

Authorized By: **Jeff Schwartz**, Program Coordinator
Fire Engineering & Investigations Division